



# North Bihar Power Distribution Company Limited

## Proceeding of Review Meeting of Siwan & Saran Districts under Chairmanship of MD, NBPDCL.

Date : 18-01-2016		Place : Siwan & Saran
Sl. No.	Observation/ Direction	Responsible Officer
1	Consumer Indexing for Siwan Town is still pending for around 18048 consumers as of now. This has been taken very seriously. It has been directed that the list should be circulated section wise and by Feb -16, this work has to be completed.	EEE(S) AEE(S) RAPDRP Cell
2	The progress of data availability of distribution transformer in MDM is only one 125 out of 216. Concerned AEE Siwan(Urban) has no idea regarding the lower percentage of data communication. It has been directed that its compliance should be 100% by Jan-16.	EEE(S) AEE(S) RAPDRP Cell
3	<p>The policy regarding providing training for SAP and different modules in RAPDRP to only concerned engineers/officers of RAPDRP Town is not sufficient as people from other areas be transferred/posted to RAPDRP Town could not take over the process/function/working of utility being implemented through SAP.</p> <p>It has been directed to RAPDRP Cell and Reliance to impart training to all engineers of the company and also to all officers handling the revenue/accounts department. This training should be provided at division level and roster should be prepared for providing this training at field/company level. Wide publication/circulation of Training manual has to be done before and after the training as required. This manual should clearly emphasize the different aspects/functioning of different modules under RAPDRP.</p>	RAPDRP Cell
4	<p>It has been found the meter utilization certificate is only reconciled as per the utilization certificate being submitted by concerned section/sub-division to MRT/Store. But even after this report it is found that there is a huge gap between (i) Meter Issued (ii) Meter utilized &amp; (iii) Meters brought in billing cycle. ESE concerned should take this task of getting the meters in billing cycle which had already been issued. The utilization should only be confirmed according to the meters being brought in billing cycle.</p> <p>During the entire process if it is detected that</p> <p>(i) The gap between the utilization and meter issued is up to 80% then immediate salary should be held up of concerned JEE till he submit the utilization of 50% of his un-utilized meters.</p> <p>(ii) Greater than 80% then immediate salary should be held up of concerned JEE and stern disciplinary action/departmental proceeding has to be initiated against the concerned JEE.</p>	Metering Cell ESE(S) EEE(S) JEE(S)
5	GM(Revenue) should formulate plan for opening PL account of each division.	GM(Rev)

Sl. No.	Observation/ Direction	Responsible Officer
6	M/s GKC Co. is doing electrification work in RGGVY 11 <sup>th</sup> Plan Phase-II in Siwan district. There is a huge gap between the physical progress of the nos. of village electrified and the document submitted for verification. As on date the progress of village electrification under IEV is 711 and document submitted and taken over is only 394. This gap has to be monitored.	Project-I EEE(Project)
7	Mobile No. updation/entry of consumers has to be entered in billing database. RO of concerned division should be held responsible if 100% mobile no. entry in consumer database is not done up to Feb-16.	Revenue Cell RO IT Department
8	AT&C loss of Siwan division has jumped from 41% to 48%. This is area of concern . It has been directed that at least 1000 disconnections per month of (NDS, LTIS & DS-2) Consumers has to be done. New connection has to be billed on meter reading immediately.	Revenue Cell EEE(S)
9	Training should be imparted to all concerned regarding various Mobile Apps being Launched/Running in DISCOM. The mobile app for PSS monitoring has to be implemented and all the concerned JEE & SBO should report accordingly.	IT Department
10	Store building of Siwan is in dilapidated condition. ESE(S&P) Sri Birendra Prasad & CE(Civil) Sri Ajay Kumar Sinha should physically inspect the site and take decision for its renovation.	CE(Civil)
11	<p>There should be zero tolerance regarding corruption in any form in rural electrification/Project work. It should be mandatory that a meeting has to be organised by EEE(Project)/ AEE(Project)/JEE(Project) with local people representative, Mukhiya, Sarpanch of concerned village and a proceeding regarding this meeting has to be issued same day that the village electrification work is a government scheme and there is complete transparency in the work. In no case by any means complain regarding corruption has to be tolerated. Immediate action has to be taken against the concerned person/agencies if found so.</p> <p>Director(Project) should circulate a model format regarding the "<b>Awareness Program</b>" through a public notice which has to be fixed in at the local schools/public places in the village.</p>	Director(P) Project-I EEE(P)
12	The progress in providing connection to be BPL household is very low. Only 35753 BPL connection has been achieved against target of 2.8 Lacs. This is a huge difference. It has been directed that 14 JEE(supply) & 2 JEE(Project) of Siwan district should perform test check regarding the poor progress in BPL and they should submit a report through EEE(Project).	Project-I
13	There are 10 New upcoming PSS in RGGVY 11 <sup>th</sup> Plan Phase-II in Siwan District. The connectivity for these PSS is still not finalised. The existing PSS is already connected through tapping of another 33 KV line or line in line out basis. So it should be examined for connectivity of this upcoming PSS through upcoming GSS in the district. The Scope and plan need to be revisited for sustain power supply in the district.	Project-I EEE(P) EEE(S)