

**NORTH BIHAR POWER DISTRIBUTION CO. LTD., PATNA**

(Registered Office, Vidyut Bhawan, Bailey Road, Patna)

(Department of Rural Electrification)

Letter No.- N-XII/RGGVY/GTP &amp; Drawing/Katihar/Cabcon-1219/2016-

Date-

E-mail-cere.bseb@gmail.com

From,

**S.K. Srivastava**  
Chief Engineer (Project-I)

To,

**M/s Cabcon India Pvt. Ltd.**  
1<sup>st</sup> Floor, The Terminus Building  
BG-12, Action Area-1B, New Town  
Kolkata-700156, Phone-033 40365000

Sub:-

**Regarding approved GTP, Drawing of M/s Hightension Electrical Equipments**

Ref:-

**Your letter no.- 141 dated 30.11.2016**

Sir,

Please find enclosed herewith approved GTP/Drawing of following Items submitted by you vide letter under reference as per REC/TS, 11<sup>th</sup> Plan RGGVY work and valid type test report for Katihar District.

S.N.	Material Description	Vendor Name
1	11 KV Danger Board	M/s Hightension Electrical Equipment Pvt. Ltd., Howrah

It may please be noted that approval of GTP/Drawing of subject material does not absolve you of contractual responsibility in terms of its quality etc in case any problem/ issue with regard to material/vendor arises at any stage, NBPDCCL reserves the right of withdrawal of this approval as well as ask the turnkey contractor to replace the materials at their own cost immediately.

Encl:- As above

Yours faithfully

Sd/-

**(S.K. Srivastava)**

Chief Engineer (Project-I)

Memo No.-

Date-

Copy with a copy of approved GTP, Drawing forwarded to ESE, Electric Supply Circle, Purnea/EEE (Project), Electric Supply Division Katihar for information and necessary action.

Encl:-As above

Sd/-

**(S.K. Srivastava)**

Chief Engineer (Project-I)

Memo No.-

Date-

Copy forwarded to M/s Techno Electric & Engg. Co. Ltd., Skipper corner 88, Nehru Phase, New Delhi/M/s EMC Ltd., Dr U. N. Bronaidrai Street, 5th floor, South floor, Kolkata/M/s Bajaj Electricals Ltd., Bhanu Shankar yagnik Marg, Mumbai-400022/M/s East India Udyog Ltd., 145, G.T. Road, Sahibabad, Ghaziabad/M/s Polycab Wires Pvt. Ltd., Polycab House, 771, Pandit Satwalekar Marg, Mumbai/ M/s Energo Engineering Projects Ltd., Okhla, Phase II, New Delhi/M/s Technofab Engineering Ltd., Nehru Place, New Delhi/M/s Techno Power Enterprises (P) Ltd., Nepali Basti, Dimapur, Nagaland/M/s L & T Ltd., Post Box-979, Mountpoomaamlee Road, Manappakkam, Chennai-600089/M/s Lumino Industries Ltd. 307, Swaika center, 4A, Pollock Street, Kolkata/ M/S Shirdi Sai Electricals Ltd.,13/82, Industrial estate, Kadapa, Andhra pradesh-516004,Ph no-0779988 for information and necessary action.

Encl:-As above

Sd/-

**(S.K. Srivastava)**

Chief Engineer (Project-I)

Memo No.-

6538


Date- 03-12-16

Copy forwarded to Electrical Executive Engineer (IT), North Bihar Power Distribution Company Limited to upload this information and GTP & Drawing on NBPDCCL website.

Encl:-As above

**(S.K. Srivastava)**

Chief Engineer (Project-I)



*This shall be conforming to RBC T.S. 12 plus B664/1/DDUGJY.*  
**Checked**

*[Signature]* AEE(RE)     *[Signature]* EEE(RE)     *[Signature]* ESE(RE)

**Approved**

*[Signature]*  
 CE (Project, I)  
 NBPDC, Patna

**NOTES-**

1. ALL DIMENSIONS ARE IN MM.
2. GENERAL TOLERANCE ~~±0.2~~ As per IS



<b>CABCON</b>		
PROJECT	Full Scale Rural Electrification of balance works under XI Plan of Katihar District Under deen Dayal Upadhyay Gram Jyoti Yojana	
OWNER	NORTH BIHAR POWER DISTRIBUTION COMPANY LIMITED	
NAME OF MANUFACTURER		
LOA NO.	For Supply	N-XIII/Tender/F SEKATIHAR/XIth Plan-1123/2016 3905 dated 29.06.2016
	For Erection	N-XIII/Tender/F SEKATIHAR/XIth Plan-1123/2016 3906 dated 29.06.2016
<b>HIGHTENSION ELECTRICAL EQUIPMENTS PVT. LTD.</b> (Formerly Hightension Electrical Industries) Unit I: 101 'C' Road, Belgachia, P.O- Dasnagar, Howrah- 711 105 (W.B) India. Unit II: 97/7 'C' Road, Belgachia, P.O- Dasnagar, Howrah- 711 105 (W.B) India.		
DRG. TITLE: 11 KV DANGER BOARD		
DRG. NO.: HEEPL/DB/0019	REV- 0	
SCALE- N.T.S	DRN. BY- A.M.     CHEKD. BY- S.K.J     SHT. NO.- 1 OF 1	

*[Handwritten mark]*


1210


PROJECT		Full Scale Rural Electrification of balance works under XI Plan of Katihar District Under deen Dayal Upadhyay Gram Jyoti Yojana
LOA NO	For Supply	N-XIII/Tender/FSEKATIHAR/XIth Plan-1123/2016 3905 dated 29.06.2016
	For Erection	N-XIII/Tender/FSEKATIHAR/XIth Plan-1123/2016 3906 dated 29.06.2016
OWNER		NORTH BIHAR POWER DISTRIBUTION CO. LTD., PATNA
CONTRACTOR		M/S CABCON INDIA PVT. LTD., Kolkata: 700001
NAME OF SUPPLIER		M/s. HIGHTENSION ELECTRICAL EQUIPMENTS PVT. LTD ( formerly Hightension Electrical Industries) 101, 'C' ROAD, BELGACHIA, P.O.: DASNAGAR, HOWRAH – 711105 (WB) INDIA.
NATURE OF PRODUCT		11 KV DANGER BOARD

**GUARANTEED TECHNICAL PARTICULARS OF 11 KV DANGER BOARD**

Sl.No.	Description	Requirement	Offered Value
1	Makers Name and address		<b>Hightension Electrical Equipments Pvt. Ltd.,</b> (formerly Hightension Electrical Industries) OFFICE & WORKS: - 101, 'C' ROAD, BELGACHIA, P.O.: DASNAGAR, HOWRAH – 711 105.
2	Size of Danger Board	For High & Extra High installation 250 x 200mm	Size of Danger Board 11000 V 250 x 200mm
3	Material	Mild Steel plate <i>least 1.6 mm thick</i>	Mild Steel plate <i>least 1.6 mm thick</i>
4	Front side of Board	Dully vitreous Enameled white, with letters figures and conventional skull and cross – bones in signal red color on the front side (refer IS-5-1978)	The plate is Vitreous Enameled with white and letters etc. with red color. The size of letters etc is as per IS: 2551 / 1982 <i>Skull and cross bones in signal red color on the front side (refer IS-5-1978)</i>
5	Rear side of Board	Rear side of the plate shall also be enameled	Rear side of the plate is black enameled.
6	Holes	10mm dia holes at suitable place as per sketch for fixing	10mm dia holes at suitable place as per sketch for fixing
7	Languages	In local & English language as per sketch	The language will be Hindi and English
8	Drawing No.	HEEPL/DB/0019	

*This shall be conforming to REC, T.S. 12th plan REGVY/DBUGY.*

**Checked**  
 AEE(RE)  
 EEE(RE)  
 ESE(RE)

**Approved**  
  
 CE (Project, I)  
 NBPDC, Patna

